



<b>Object:-</b>	<b>Dorman 8JT</b>		
<b>Object ID:-</b>	4135	<b>Accession No:-</b>	IF:2012:155
<b>Date:-</b>	1971-04-30	<b>Works Number:-</b>	
<b>Category:-</b>	Engine		
<b>Collection:-</b>	Internal Fire Core Collection		
<b>Manufacturer:-</b>	W. H. Dorman and Co. Ltd		
<b>Made In:-</b>	Stafford, England		

<b>Description:-</b>
186kva 3-phase generating set.

<b>Location:-</b>	
<b>Status:-</b>	On Display
<b>Condition:-</b>	Running

<b>Conservation/Maintenance:-</b>
2013-10-19 Initial Assessment Engine pressure washed off and treated with preservative. Control panel recently removed with all pipes and connections cut. Throttle linkages seized and solenoid damaged Canopy requires welding and hinge replacement on all access panels
2014-10-11 Progress Report Work done by Paul James (ex Dorman Service Manager). Engine checked over, new control panel fabricated, throttle linkages sorted Engine turns over with oil pressure, just requires fuel system cleaning for first run.

